



WQMIS

Jal Jeevan Mission

Har Ghar Jal



District PHED Laboratory Dausa

PHED District Laboratory, Near Khan Bhakri Road Collectrate Circle Dausa (Test Address only)

Test report

Sample ID:

U1408537511652981

User Information

Name:

Radha Kishan Meena

Mobile:

9636264792

Email:

Aenr.phed@gmail.com

Pin Code:

Full Address:

Village- Not available , Gram Panchayat- Not available, Block- Not available, District- Dausa, State- Rajasthan

Sample description

Source of Sample:

Private Tube well / Bore well / Well, location : vidyasthali public

Village:

Nangal Bersi

Gram Panchayat:

Nagalbersi

Block:

Dausa

District:

Dausa

State:

Rajasthan

Address:

Remarks:

Latitude:

Longitude:

Date & time of sample collection

24.04.2023 | 12:10:00 PM

Date & time of sample received in lab

25.04.2023 | 03:07:00 PM

Date & time of sample analysed

01.05.2023 | 12:47:00 PM

Date & time of report generation

01.05.2023 | 12:47:00 PM

Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (Acceptable limit) as per BIS, 1053	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Chloride (as Cl)*	mg/l	250	1000	50.000	
2	Fluoride (as F)*	mg/l		1.5	0.407	
3	Nitrate (as NO3)*	mg/l		No Relaxation	4.000	
4	pH*	NA	6.5-8.5	No Relaxation	7.600	
5	TDS*	mg/l	500	2000	200.000	

Sectional Seal
Vidyaasthali Public School
 Vidyasthali Bairsi Road
 NH-11, Nangal, Dausa (Raj)

Sr No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS-33501	Permissible limit in absence of alternative source) as per BIS 105-00	Test result value	Remarks
6	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	70.000	
7	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
8	Total Hardness (As CaCO3)*	mg/l	200	600	50.000	

Note:

- 1) *indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above
- 3) The report shall not be reproduced in full without approval of authority
- 4) This is the end of the report

Authorised signatory
Rajesh Bharatiya (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NLC, Copyright ©copy NJUM 2023


Secretary
 Vidyaasthali Public School
 NH-11, Nangal Bairol Road
 Dausa (Raj.)